



SYSTEM DESCRIPTION

1. DOORS CLOSED AND LOCKED.
2. ACTIVATION OF I:BUTTON WILL RELEASE LOCKS.
3. ACTIVATION OF 653-04 KEY SWITCH MAINTAINS LOCKS IN UNLOCKED POSITION.
4. LOCKS CONFIGURED FOR 24 VDC OPERATION.
5. ACTIVATION OF FIRE ALARM RELEASES LOCKS.

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED. MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. X UNUSUED CONDUCTORS. INSULATE AND STORE.