

- NOTES**
1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
  2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
  3. —X UNUSED CONDUCTORS. INSULATE AND STORE.
  4. USE 12 GAUGE WIRE FOR RED & BLACK EL POWER WIRES
  5. 200 FEET MAXIMUM WIRE RUN
- THIS WIRING INFORMATION IS BEING PROVIDED BASED ON CUSTOMER SUPPLIED EQUIPMENT LIST AND FUNCTIONAL DESCRIPTION, AND MAY BE SUBJECT TO APPROVAL BY THE AUTHORITY HAVING JURISDICTION

**SYSTEM OPERATION**  
 SYSTEM MUST BE RESET BY KEY SWITCH ON POWER UP IN ORDER TO LOCK DOOR  
 DEPRESSING PANIC BAR WILL TOGGLE MAGNETIC LOCK OFF  
 ACTIVATION OF KEY SWITCH WILL ONLY RELOCK DOOR

