

**NOTES**

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR. COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3.        X UNUSED CONDUCTORS. INSULATE AND STORE.
4. USE 12 GAUGE WIRE FOR RED & BLACK EL POWER WIRES
5. 200 FEET MAXIMUM WIRE RUN
6. THIS WIRING INFORMATION IS BEING PROVIDED BASED ON CUSTOMER SUPPLIED EQUIPMENT LIST AND FUNCTIONAL DESCRIPTION, AND MAY BE SUBJECT TO APPROVAL BY THE AUTHORITY HAVING JURISDICTION

**SYSTEM OPERATION**  
 SYSTEM SHOWN WITH ALL DOORS CLOSED AND SECURED  
 ACTIVATION OF ANY CT1000 OR 620 PUSH BUTTON  
 WILL RELEASE CORRESPONDING DOOR AND PREVENT  
 OTHER DOORS FROM OPENING  
 ACTIVATION OF FIRE PANEL OR 740 BREAK GLASS  
 SWITCH WILL RELEASE ALL DOORS

