

**NOTES**

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. —X UNUSED CONDUCTORS. INSULATE AND STORE.

**SYSTEM OPERATION**

DOOR SHOWN CLOSED AND SECURED  
 ENTERING CORRECT CODE INTO KEY WILL RELEASE THE STRIKE FOR ACCESS  
 FREE EGRESS BY LOCK SET  
 STRIKE WIRED FOR 24VDC

