

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. —X UNUSED CONDUCTORS. INSULATE AND STORE.

SYSTEM OPERATION

DOOR SHOWN CLOSED AND SECURED
 ENTERING CORRECT CODE INTO KEY WILL RELEASE THE MAGLOCK FOR ACCESS
 DEPRESSING THE TOUCH BAR WILL RELEASE THE MAGLOCK FOR EGRESS

