

- NOTES
1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
 2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
 3. — X UNUSED CONDUCTORS. INSULATE AND STORE.

ITEM	DESCRIPTION	PART NUMBER	QTY
1	POWER SUPPLY	505 SERIES	1
2	ELECTRIC LOCK	70 SERIES	1
3	KEY PAD	PRO78	1
4	TOUCH BAR	692-36 628-RD	1
5	DOOR CORD	798-12	1
6	PUSH BUTTON SWITCH	621-RD EX x DA	1

