



- NOTES**
1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
 2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
 3. _____ X UNUSED CONDUCTORS. INSULATE AND STORE.
 4. USE 12 GAUGE WIRE FOR RED & BLACK EL POWER WIRES
200 FEET MAXIMUM WIRE RUN
 5. THIS WIRING INFORMATION IS BEING PROVIDED BASED ON CUSTOMER SUPPLIED EQUIPMENT LIST AND FUNCTIONAL DESCRIPTION, AND MAY BE SUBJECT TO APPROVAL BY THE AUTHORITY HAVING JURISDICTION

- SYSTEM DESCRIPTION:**
1. DOORS SHOWN CLOSED AND LOCKED.
 2. CONSOLE PUSHBUTTON WILL RELEASE MAGLOCKS.
 3. MBS MONITORED BY GREEN LED, GREEN LED LIT WHEN MAGNET IS SECURE.
 4. DSM MONITORED BY RED LED, RED LED LIT WHEN DOOR IS CLOSED.
 5. CONSOLE PUSHBUTTONS CAN BE LOCKED OUT BY KEYSWITCH ON CONSOLE.