



SYSTEM DESCRIPTION:

1. FAIL SAFE LOCKS, DOORS CLOSED AND LOCKED
 2. OPEN DOOR A, LOOKS B.C.
 3. OPEN DOOR B, LOOKS A.C.
 4. OPEN DOOR C, LOOKS A.B.
 5. ALL LOCK CONTROL IS FROM 8208 CONSOLE.
- CONSOLE SHOWS GREEN LIGHT WHEN DOOR IS SECURE.
 CONSOLE SHOWS RED LIGHT WHEN DOOR IS UNSURE.
 * PLEASE NOTE: CUT ALL DIODES SPECIFIED IN 8200 CONSOLE MANUAL. (PAGE 9)

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. —X UNUSED CONDUCTORS. INSULATE AND STORE.