

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. _____ X UNUSED CONDUCTORS. INSULATE AND STORE.

SYSTEM OPERATION

- DOOR NORMALLY LOCKED
- ACTIVATION OF CT1000 WILL UNLOCK 390+ LOCK
- DEPRESSING 620 PUSH-BUTTON WILL RELEASE LOCK
- RED LED = DOOR IS LOCKED, GREEN LED = DOOR IS UNLOCKED
- YELLOW LED IS FOR BACK LIGHT ONLY
- ALARM RELAY WILL ACTIVATE IF DOOR IS OPENED LONGER THAN 30 SECONDS
- ACTIVATION OF FIRE PANEL WILL RELEASE LOCK

