



SYSTEM OPERATION

SYSTEM SHOWN CLOSED AND SECURED
 ACTIVATION OF CHEXIT DEVICES WILL RELEASE DOORS IN 15 OR 30 SECONDS
 L1910S-1 HORN/STROBE WILL SOUND TILL CHEXIT BAR IS RESET
 THE 2 621RDxNS WILL RELEASE AND RESET CORRESPONDING DEVICES
 THE 643-15 WILL RELEASE AND RESET BOTH DEVICES
 ACTIVATION OF THE 643-05 WILL DEACTIVATE DEVICE FOR INGRESS
 THE 6200 TIMER WILL ALLOW SYSTEM DEACTIVATION AT PRESET TIMES
 ACTIVATION OF FIRE PANEL WILL DEACTIVATE SYSTEM

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. X UNUSED CONDUCTORS. INSULATE AND STORE.