



NOTES

1. 653-04 KEYSWITCH LOCKS OR UNLOCKS BOTH SHEAR LOCKS
2. EITHER PUSHBUTTON (621RDEXxDA) WILL MOMENTARILY UNLOCK BOTH SHEAR LOCKS
3. ACTIVATION OF FIRE PANEL UNLOCKS BOTH SHEAR LOCKS

NOTES

1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
3. _____ X UNUSED CONDUCTORS. INSULATE AND STORE.