

- NOTES
1. ALL LOW VOLTAGE WIRING TO BE STRANDED, MULTI-CONDUCTOR, COLOR CODED WIRE WITHOUT SPLICES. A MINIMUM OF TWO SPARE CONDUCTORS IS RECOMMENDED. WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES FOR CLASS 2 FIRE PROTECTION SIGNALING AND CONTROL DEVICES.
 2. REFER TO DOCUMENTATION SUPPLIED WITH PRODUCT FOR IMPORTANT INFORMATION REQUIRED FOR PROPER INSTALLATION.
 3. — X UNUSED CONDUCTORS. INSULATE AND STORE.

SYSTEM OPERATION
 ACTIVATION OF LCN ACTUATOR WILL UNLOCK DOOR AND OPERATE THE LCN OPERATOR
 653 KEY SWITCH WILL DISABLE ACTUATOR

